



- NOTES
1. ARRANGEMENT AND DIMENSIONS FOR TYREE KIOSK SUBSTATIONS ONLY.
 2. FOR PLINTH DETAILS REFER:
500 KVA: K-302.
750KVA AND 1000 KVA: K-303.
1500KVA AND 2000 KVA: KS-304
 3. FOR CONDUIT DETAILS REFER:
500 KVA: D-809-0050-SD-001
750KVA AND 1000 KVA: D-809-0052-SD-001.
1500KVA AND 2000 KVA: D-809-0055-SD-001.
 4. FOR EARTHING SYSTEM DETAILS REFER:
500 KVA: K-309.
750KVA AND 1000 KVA: K-310.
1500KVA AND 2000 KVA: K-311.
 5. FOR CIVIL FOUNDATIONS REFER:
500 KVA: D-809-0049-SD-001.
750KVA AND 1000 KVA: D-809-0051-SD-001.
1500KVA AND 2000 KVA: D-809-0054-SD-001.

TYREE KIOSK DIMENSIONS

| SIZE | L | W | H | L1 | W1 | MASS (kg) |
|----------|------|------|------|-----|-----|-----------|
| 500 kVA | 2950 | 1380 | 1702 | 654 | 652 | 3905 |
| 750 kVA | 3340 | 1510 | 1822 | 759 | 765 | 4960 |
| 1000 kVA | 3340 | 1510 | 1822 | 759 | 765 | 5550 |
| 1500 kVA | 3660 | 1830 | 1992 | 874 | 765 | 7450 |
| 2000 kVA | 3660 | 1830 | 1992 | 874 | 765 | 8855 |

DIMENSIONS ARE IN MILLIMETRES
UNLESS OTHERWISE STATED

ALTERATIONS

ORIGINAL ISSUE

DETAILS FOR 1500KVA AND 2000KVA KIOSKS ADDED.

B

TasNetworks

PROJECT 000000

DESIGNED BY G.HALL

DATE 19/10/2023

DESIGNED BY B. NARAYANASAMY

DATE 19/10/2023

DESIGNED BY J. HUGHES

DRAWN G.HALL

DESIGNED BY G.HALL

CHECKED BY B. NARAYANASAMY

APPROVED BY J. HUGHES

DATE APPROVED 29/AUG/2023

© Tasmanian Networks PTY. LTD.
trading as TasNetworks
ABN: 24 167 357 299

NO PART OF THIS DRAWING MAY BE REPRODUCED,
STORED IN A RETRIEVAL SYSTEM IN ANY FORM,
OR TRANSMITTED BY ANY MEANS WITHOUT THE
PRIOR PERMISSION OF TASNETWORKS

TITLE
TYREE KIOSK SUBSTATION
GENERAL ARRANGEMENT

D - 809 - 0047 - SD - 001

SCALE
NTS

A4

REVISION
B