


NOTES

- THESE DRAWINGS SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION, MECHANICAL, CIVIL AND RELEVANT ENGINEERING STANDARDS, DOCUMENTS AND WITH OTHER SUCH WRITTEN INSTRUCTIONS AS MAY BE ISSUED.
- ALL EXCAVATION SHALL BE CARRIED OUT IN SUCH A MANNER AS TO PRESERVE UNDISTURBED CONDITIONS AT THE UNDERSIDE OF THE BEDDING AND ENGINEERED FILL.
- FOLLOWING EXCAVATION, CONDUCT DCP TESTS AT THE CORNERS AND IN THE MIDDLE OF THE SLAB. DCP TESTS SHALL BE CONDUCTED IN ACCORDANCE WITH RELEVANT AUSTRALIAN STANDARDS AND ALL TEST VALUES RECORDED AS EVIDENCE OF COMPLIANCE.
- THIS DESIGN IS ONLY SUITABLE WHERE SUBGRADE DCP IS GREATER THAN OR EQUAL TO 3. IF UNACHIEVABLE, A CERTIFIED CIVIL DESIGN SHALL BE DEVELOPED.
- BEDDING MATERIAL SHALL BE SAND (FREE OF GRAVEL/LARGER PARTICLES) PLACED AS CONTROLLED FILL & COMPACTED IN LAYERS LESS THAN 200mm THICK WITHIN A DEFINED MOISTURE RANGE BY SUITABLE EQUIPMENT. COMPACTION SHALL SATISFY THE REQUIREMENTS OF AS 2566.1 HAND TAMP, AND WATER SAND AROUND THE CONDUIT HAUNCHES AND TO 150mm ABOVE THE TOP OF THE CONDUIT. ABOVE THIS LEVEL PLACE SAND AS CONTROLLED FILL.
- ENGINEERED FILL SHALL COMPLY WITH DEPARTMENT OF STATE GROWTH (DSG), ROADWORKS SPECIFICATION R40 (PAVEMENT BASE 'A').
- COMPACTED ENGINEERING FILL SHALL BE PLACED AND COMPACTED IN 150MM MAXIMUM THICK LAYERS. IN ACCORDANCE WITH DSG SPECIFICATION R40.
- MINOR IMPERFECTIONS IN THE SURFACE OF THE ENGINEERED FILL OF UP TO ± 10 mm SHALL BE FILLED AND SCREENED WITH BEDDING SAND TO ACHIEVE A LEVEL SURFACE.
- FOR PLINTH DETAILS REFER TO KS-302.
- FOR EARTH GRID DETAILS REFER TO D-KS1-???
- FOR CONDUIT DETAILS REFER TO D-KS1-???
- UNDERGROUND TRENCH ARRANGEMENTS TO BE COMPLIANT WITH UNDERGROUND DESIGN STANDARD.
- TRENCH WIDTH MUST ALLOW FOR A MINIMUM CLEARANCE OF 75mm EACH SIDE OF CABLE OR CONDUIT.

DIMENSIONS ARE IN MILLIMETRES
UNLESS OTHERWISE STATED

ALTERATIONS	ORIGINAL ISSUE			© Tasmanian Networks PTY. LTD. trading as TasNetworks ABN: 24 167 357 299		NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT THE PRIOR PERMISSION OF TASNETWORKS	
				TITLE		SCALE	
				TYREE 500kVA KIOSK SUBSTATION CIVIL FOUNDATIONS		NTS	
		DRAWN		G.HALL			
		DESIGNED BY					
		CHECKED BY		B. NARAYANASAMY		A4	
		APPROVED BY		J.HUGHES			
DATE APPROVED		29/AUG/2023		D - 809 - 0049 - SD - 001		REVISION A	