

LEGEND:

 FIRE RISK ZONE 2 - NO EXTERNAL COMBUSTIBLE MATERIAL WITHIN ZONE



DOORS AND VENTS NOT REQUIRED TO BE FIRE RATED

ALL SUBSTATION WALLS TO FRL 120/120/120

ELEVATION 1:150

NOTES:

1. MINIMUM SEPARATION DISTANCES FOR FIRE RATED KIOSK TYPE SUBSTATIONS CONTAINING LESS THAN 1000 LITRES OF OIL INSTALLED IN A LOW DENSITY RESIDENTIAL AREA.
2. FOR SUBSTATIONS WITH FIRE RATED WALLS AND ROOFS AND NON FIRE RATED VENTS AND DOORS.
3. VENT OPENINGS SHALL NOT EXCEED 600 x 600mm
4. A SITE ASSESSMENT SHALL BE UNDERTAKEN TO CONFIRM SEPARATION DISTANCES ARE ACCEPTABLE.
5. ENCROACHMENT INTO ZONE 2 SHALL NOT OCCUR WITHOUT AN APPROVED FIRE RISK ASSESSMENT.
6. COMBUSTIBLE MATERIALS INCLUDE, BUT ARE NOT LIMITED TO TIMBER, CEMENT SHEETS (EAVES), ROOFING MATERIALS ETC.

ALTERATIONS			TasNetworks PTY. LTD. ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.	
	DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE		KIOSK SUBSTATION FIRE PROTECTION GUIDE FIRE RATED ENCLOSURE	
	DRAWN C5 PRO-SOLUTIONS		CHECKED G.HALL		APPROVED 	
	DATE 05/02/2016		KS-203		SCALES 1:150 SIZE A4 REVISION A	