



ISOMETRIC VIEW

1:75

- NOTES:
1. RETAINING WALLS SHALL NOT BE HIGHER THAN 600mm. RETAINING WALLS HIGHER THAN 1m SHALL HAVE AN APPROVED CIVIL DESIGN
  2. SOLID CONCRETE BLOCKS SHALL BE USED. CAPPING PAVERS SHALL NOT BE USED.
  3. RETAINING WALL FOUNDATION SHALL BE COMPACTED ENGINEERED FILL WITH A MINIMUM DEPTH OF 150mm.
  4. APPROPRIATE DRAINAGE SHALL BE PROVIDED TO PREVENT WATER POOLING AROUND THE KIOSK/SWITCHING STATION.
  5. A 'V'NOTCH DRAIN SHALL BE PROVIDED AT THE BASE OF THE RETAINING WALL.
  6. THE DESIGN SHALL ENSURE THAT NO UNEVEN SURFACES ARE PRESENT THAT MAY CREATE TRIP HAZARD.
  7. DISTURBED SURFACES SHALL BE REINSTATED WITH APPROPRIATE GROUND COVER
  8. RETAINING WALL AND ASSOCIATED INFRASTRUCTURE SHALL BE WITHIN THE EASEMENT.
  9. CONSIDERATION SHALL BE MADE FOR DRAINAGE AT THE SITE FOR ENSURING THAT WATER RUN OFF DOES NOT ADVERSELY IMPACT THE SURROUNDING AREA.

ALTERATIONS

 <b>TasNetworks</b>		TasNetworks PTY. LTD. ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.	
DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE  KIOSK/MINIKIOSK/SWITCHING STATION RETAINING WALLS			SCALES  1:75
DRAWN	C5 PRO-SOLUTIONS				SIZE A4
CHECKED	G.HALL	KS-207			REVISION A
APPROVED	 DAVID ELLIS 05/02/2016				DATE