






LEGEND:

OPERATION & ACCESS ZONE

NOTES:

1. CARE SHOULD BE TAKEN NOT TO DAMAGE THE EXISTING STRUCTURES DURING INSTALLATION.
2. SURROUND TO BE GRADED TO CONCRETE PAD, NATURAL GROUND AND FOOTPATH AND TO ALLOW NATURAL DRAINAGE.
3. SWITCHING STATION LIFTING HOLES TO BE KEPT CLEAR.
4. GROUND IN VICINITY OF SWITCHING STATION TO BE REINSTATED AFTER CONSTRUCTION IS COMPLETED.
5. SWITCHING STATION BASE NOT SHOWN.
6. FOR PROPOSED SWITCHING STATION CHOOSE STRAIGHT ROAD IF AVAILABLE.
7. REFER TO DRAWING KS-202 FOR CLEARANCES RELATED TO FIRE RISK.
8. OPERATIONAL DOORS SHOULD FACE ROAD.

ALTERATIONS UPDATED CLEARANCE REQUIREMENTS	 <b>TasNetworks</b>			 <b>TasNetworks</b>	TasNetworks PTY. LTD. ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.								
	REV	B	PROJECT		TITLE				SCALES AS INDICATED						
	DESIGNED BY	ALEX MCKAY	ENGINEERING CHECK		SWITCHING STATION GUIDE FOR SITE SELECTION 3-4 RMU				SIZE A4						
	DATE	27/05/2024	DATE						27/05/2024						
REV	B	PROJECT	DRAWN	C5 PRO-SOLUTIONS	CHECKED	G.HALL	APPROVED  DAVID ELLIS 05/02/2016	DATE	05/02/2016	KS-339	REVISION B				
			DRAWN	C5 PRO-SOLUTIONS		CHECKED						G.HALL	APPROVED  DAVID ELLIS 05/02/2016	DATE	05/02/2016
			DRAWN	C5 PRO-SOLUTIONS								CHECKED			
			DRAWN	C5 PRO-SOLUTIONS		CHECKED							G.HALL	APPROVED  DAVID ELLIS 05/02/2016	DATE