




EARTH CONNECTION DIAGRAM
NTS

NOTES:
1. MINIMUM OF TWO 70mm² COPPER CONNECTION TO EARTH GRID. FOR FURTHER DETAILS REFER TO KS-344

ALTERATIONS UPDATED TO SUIT NEW STANDARD RM6 EQUIPMENT			TasNetworks DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		 TasNetworks TasNetworks PTY. LTD. ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.					
REV	B	PROJECT	DESIGNED BY	ALEX MCKAY	C5 PRO-SOLUTIONS	DRAWN BY	C5 PRO-SOLUTIONS	TITLE	SWITCHING STATION EARTH CONNECTION DIAGRAM	SCALES NTS		
			ENG-CHECK	A.MCKAY	DATE	27/05/2024						
			ENG-APPROV.	J.HUGHES	DATE	27/05/2024						
			APPROVED			CHECKED	G.HALL					
			DATE	DAVID ELLIS 05/02/2016					KS-343	REVISION B		