



AL T E R A T I O N S	ORIGINAL ISSUE		V CONDUIT SPACING REVISED.		<div>TasNetworks <small>DRAWN BY G.HALL</small> <small>CHECKED BY A.MCKAY</small> <small>DATE 3/11/2023</small> <small>SCALE 1:100</small> <small>DATE 3/11/2023</small></div>
	B				
DRAWN		G.HALL		<div>TasNetworks</div>	
DESIGNED BY		G.HALL			
CHECKED BY		A.MCKAY			
APPROVED BY		J.HUGHES			
DATE APPROVED		29/AUG/2023			
© Tasmanian Networks PTY. LTD. trading as TasNetworks ABN: 24 167 357 299					UNLESS OTHERWISE STATED NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT THE PRIOR PERMISSION OF TASNETWORKS
TITLE					SCALE
TYREE 500KVA KIOSK SUBSTATION CONDUIT DETAILS					NTS
D - 809 - 0050 - SD - 001					REVISION B
					A4