



LEGEND:

-  FIRE RISK ZONE 1 - NO MATERIALS TO BE INSTALLED WITHIN ZONE, EXCEPT FOR FIRE RATED FRL 120/120/120 MATERIAL OR INTEGRATED ELECTRICAL EQUIPMENT.
-  FIRE RISK ZONE 2 - NO EXTERNAL COMBUSTIBLE MATERIAL WITHIN ZONE

1. MINIMUM SEPARATION DISTANCES FOR NON-FIRE KIOSK TYPE SUBSTATIONS CONTAINING LESS THAN 1000 LITRES OF OIL INSTALLED IN A LOW DENSITY RESIDENTIAL AREA.
2. A SITE ASSESSMENT SHALL BE UNDERTAKEN TO CONFIRM SEPARATION DISTANCES ARE ACCEPTABLE,
3. ENCROACHMENT INTO ZONE 2 SHALL NOT OCCUR WITHOUT AN APPROVED FIRE RISK ASSESSMENT.
4. COMBUSTABLE MATERIALS INCLUDE, BUT ARE NOT LIMITED TO TIMBER, CEMENT SHEETS (EAVES), ROOFING MATERIALS ETC.

ALTERATIONS	 <b>TasNetworks</b>		TasNetworks PTY. LTD. ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.	
	DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE  KIOSK SUBSTATION FIRE PROTECTION GUIDE NON FIRE RATED ENCLOSURE			SCALES  1:150
	DRAWN	CS PRO-SOLUTIONS				SIZE A4
	CHECKED	G.HALL	REVISION A			
	APPROVED DATE	 DAVID ELLIS 05/02/2016	KS-200			