



LEGEND:

- FIRE RISK ZONE 1 - NO EXTERNAL MATERIALS TO BE INSTALLED WITHIN ZONE, EXCEPT FOR FIRE RATED FRL 120/120/120 MATERIAL OR INTEGRATED ELECTRICAL EQUIPMENT.
- FIRE RISK ZONE 2 - NO EXTERNAL COMBUSTIBLE MATERIAL WITHIN ZONE

NOTES:

1. MINIMUM SEPARATION DISTANCES FOR NON-FIRE RATED KIOSK TYPE SUBSTATIONS CONTAINING BETWEEN 1000 AND 2000 LITRES OF OIL INSTALLED IN A LOW DENSITY RESIDENTIAL AREA.
2. A SITE ASSESSMENT SHALL BE UNDERTAKEN TO CONFIRM SEPARATION DISTANCES ARE ACCEPTABLE.
3. ENCHROACHMENT INTO ZONE 2 SHALL NOT OCCUR WITHOUT AN APPROVED FIRE RISK ASSESSMENT.
4. COMBUSTABLE MATERIALS INCLUDE, BUT NOT LIMITED TO TIMBER, CEMENT SHEETS (EAVES), ROOFING MATERIALS ETC.
5. ADJACENT BUILDINGS SHALL NOT HAVE WINDOWS FACING THE KIOSK SUBSTATION.

ALTERATIONS

 <b>TasNetworks</b>		<b>TasNetworks PTY. LTD.</b> ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.	
DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE  <b>KIOSK SUBSTATION FIRE PROTECTION GUIDE OUTDOOR</b>			SCALES  <b>1:150</b>
DRAWN	CS PRO-SOLUTIONS				SIZE <b>A4</b>
CHECKED	G.HALL				
APPROVED			<b>KS-201</b>	REVISION <b>A</b>	
DATE	DAVID ELLIS 05/02/2016				