



LEGEND:

 FIRE RISK ZONE 2 - NO EXTERNAL COMBUSTIBLE MATERIAL WITHIN ZONE

NOTES:

1. MINIMUM SEPARATION DISTANCES FOR NON-FIRE RATED KIOSK TYPE SUBSTATION AND SWITCHING STATIONS THAT DO NOT CONTAIN COMBUSTIBLE LIQUID DIELECTRICS.
2. A SITE ASSESSMENT SHALL BE UNDERTAKEN TO CONFIRM SEPARATION DISTANCES ARE ACCEPTABLE.
3. ENCROACHMENT INTO ZONE 2 SHALL NOT OCCUR WITHOUT AN APPROVED FIRE RISK ASSESSMENT.
4. INDEPENDENT OF FIRE RISK ASSESSMENT, MINIMUM SEPARATION SHALL NOT BE LESS THAN 1 METRE.
5. COMBUSTABLE MATERIALS INCLUDE, BUT ARE NOT LIMITED TO TIMBER, CEMENT SHEETS (EAVES), ROOFING MATERIALS ETC.
6. ADJACENT BUILDINGS SHALL NOT HAVE WINDOWS FACING THE KIOSK SUBSTATION.

ALTERATIONS	 TasNetworks		TasNetworks PTY. LTD. ABN: 24 167 357 299	© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.
	DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE SWITCHING STATION FIRE PROTECTION GUIDE NON FIRE RATED ENCLOSURE NO COMBUSTIBLE LIQUIDS	SCALES 1:100
	DRAWN	C5 PRO-SOLUTIONS		
	CHECKED	G.HALL	KS-202	SIZE A4
	APPROVED	 DAVID ELLIS DATE 05/02/2016		REVISION A