



- NOTES:
1. WHERE ORIGINAL GROUND CONDITIONS ARE ALTERED BATTERS SHALL BE CREATED AROUND THE INSTALLATION TO REMOVE ANY STEP CHANGES IN GROUND PROFILE.
  2. THE DESIGN SHALL ENSURE THAT NO UNEVEN SURFACES ARE PRESENT THAT MAY CREATE TRIP HAZARDS.
  3. BATTERS SHALL NOT BE AT A SLOPE OF GREATER THAN 1:3.
  4. APPROPRIATE DRAINAGE SHALL BE PROVIDED TO PREVENT WATER POOLING AROUND KIOSK/SWITCHING STATION.
  5. CONSIDERATION SHALL BE MADE FOR DRAINAGE AT THE SITE FOR ENSURING THAT WATER RUN OFF DOES NOT ADVERSELY IMPACT THE SURROUNDING AREA.
  6. A V-NOTCH DRAIN SHALL BE INSTALLED AT THE BOTTOM SIDE OF BATTERS THAT ARE ADJACENT TO THE KIOSK/SWITCHING STATION.
  7. SUFACES SHALL BE REINSTATED WITH APPROPRIATED GROUND COVER.

ALTERATIONS	 <b>TasNetworks</b>		TasNetworks PTY. LTD. ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.	
	DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE		SCALES 1:50	
	DRAWN	SMECKS DRAFTING	KIOSK SUBSTATION BATTER AND DRAINAGE LAYOUT		SIZE A4	
	CHECKED	G.HALL			REVISION A	
APPROVED			KS-206			
DATE		DAVID ELLIS 05/02/2016				