



NOTES:
1. MINIMUM OF TWO 70mm² COPPER CONNECTION TO EARTH GRID FOR FURTHER DETAIL REFER TO KS-309, KS-310,KS-311 OR KS-312 RESPECTIVELY

ALTERATIONS

 TasNetworks		TasNetworks PTY. LTD. ABN: 24 167 357 299		© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.	
DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE KIOSK SUBSTATION EARTH CONNECTION DIAGRAM			SCALES NTS
DRAWN	C5 PRO-SOLUTIONS				SIZE A4
CHECKED	G.HALL	KS-308			REVISION A
APPROVED					DATE