




CAUTION : Printed document is uncontrolled.



ITEM No.	PLANT	No. OFF	MANUFACT. TYPE/REF	RATINGS	NOTES
1	CABLE	1		6.35/11kV	185 Al 3.0c XSHC PVC HDPE - 11kV
2	CABLE TERMINATION	1		11kV	TO SUIT ITEM 1
3	SWITCH	4	MERLIN GERIN	24kV 630A	GANG Op. 3PH SF6 LOAD BREAK/FAULT MAKE
4	BUSBAR	1 x 3	MERLIN GERIN	24kV 630A	SF6 INSULATED
5	ENCLOSURE	1	SCHNEIDER		3/10 KPX METAL ENCLOSURE GREEN

ALTERATIONS

 TasNetworks		TasNetworks PTY. LTD. ABN: 24 167 357 299	© COPYRIGHT - TASNETWORKS PTY. LTD. NO PART OF THIS DRAWING MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM IN ANY FORM, OR TRANSMITTED BY ANY MEANS WITHOUT PRIOR PERMISSION OF TASNETWORKS.
DIMENSIONS ARE IN MILLIMETRES. UNLESS OTHERWISE STATED.		TITLE SWITCHING STATION ONE LINE DIAGRAM	SCALES NTS
DRAWN	C5 PRO-SOLUTIONS		SIZE A4
CHECKED	G.HALL		
APPROVED	 DAVID ELLIS DATE 05/02/2016		KS-342

07/12/2015